

{Heat Pump Field Study

Phillip Kelsven – Bonneville Power Administration


Faith Debolt – SBW Consulting

Santiago Rodriguez – SBW Consulting



Why do this study?

- Understand regional installation practices of air source heat pumps, last baseline study conducted in 2005
- Bonneville Power Administration has a quality installation program – Performance Tested Comfort Systems
 - Informs program savings with updated current practice baseline
 - Informs progress region has made since interventions starting in early 2000's
 - Informs program on what to focus on, what is effective and not effective
 - Informs future regional savings potential



How did we do this study?

- Goal - Random sample of recent air source heat pump installs in single family homes
- Recruited homes that filed electric and mechanical permits data in last 3 years, data purchased from Buildfax
- Sent letters with an invite to an online survey
- If survey indicates home is eligible, call down list until geographical strata targets are met
- Visited 95 sites, half east of cascades, half west of cascades



Field Study Team




Data Collection

- Participant Interview and Survey
- Heat Pump nameplate information and thermostat settings
- Heat pump performance tests: Airflow, external static pressure, temperature split
- Duct blaster (leakage) test
- Blower door whole house air leakage test
- Home envelope and external duct audit




Use of Data


- Heat pump performance data informs how well the system was installed and commissioned
- Data from the air leakage tests (duct and whole home) along with the shell audit will be entered into two different sizing calculators
 - Regional Technical Forum developed calculator used by PTCS
 - Ecotope developed calculator developed for Idaho Power
- Regional Technical Forum will use the results to update regional Unit Energy Savings estimates





Baseline in 2005 vs 2018





Airflow




External Static Pressure



Refrigerant charge




Temperature Split




Sizing Baseline then and now


- 2005 – Units tended to be undersized by 30%
- 2019 – 39% of units were undersized by 10% or more when compared to Ecotope tool. West of cascades sites tended to be undersized at a greater rate.
- 54% of units were undersized by 10% or more when compared to PTCS tool



Heat Pump Sizing



Heat Pump Sizing




Controls – Auxiliary Lock Out


- 57% of all sites did not have the auxiliary lockout set at 35 F or below
- Excluding dual fuel sites (28%) 49% of sites did not have the auxiliary lockout set at 35 F or below
- Inefficient lockout settings tended to be set at 40F – 55F degrees
- Efficient settings tended to be set at 35F

Auxiliary Lock Out - PTCS

Excluding Dual Fuel



Including Dual Fuel




Controls – Compressor Lock Out

- At low outdoor temperatures compressors are less effective at meeting the heating load
- It is most efficient to let the compressor work at all temperatures as it will produce some part of the heating load
- If a cut out must be used it should not be cut out above 5 F



Compressor Lock Out Settings

- 28% of sites had the compressor locked out above 5 F
- Most of the 72% of sites with correct lock out had lock out disabled



What this all means...

- The baseline installation practices have not improved that much since 2005
- Refrigerant charge appears to be more of a problem than in 2005
- PTCS appears to only be most effective at ensuring the right lock out control settings
- Savings will change based on new baseline
- Still don't know what the efficient case savings are, they are modeled

